

---

## California Energy Commission (CEC) Title 20 Certification

---

California requires that all split system air conditioners be certified in compliance with the California Building Code Title 20, Chapter 2, Subchapter 4, Article 4, Section 1603(c)(2). This section is as follows:

“(2) A split system central air conditioner, or a compressor-containing unit, may be sold if, and only if, the manufacturer has certified that the compressor-containing unit, when tested with the noncompressor-containing unit most likely to represent the highest national sales volume, is in compliance with the provisions of these regulations.”

This means that the system is certified by the condensing unit manufacturer using their most common indoor coil. For the purpose of complying with Title 20, you are to use the certified ratings listed for the condenser being used. Unico, as an indoor coil manufacturer, is not required to certify the indoor unit.

Because we have a small duct system, our actual efficiency and capacity will be different than the certified performance listed with CEC. We encourage you to use the listed efficiency for the purpose of complying with Title 20. However, we also encourage you to review the performance listings in the ARI Unitary Directory so that the capacity of the system will meet the load.

Questions concerning the CEC certified units should be directed to their office at 916-654-4304. Questions concerning the Unico System should be directed to Customer Service at 314-771-7007.